

new  
ker

<b>MODEL:</b> MUSEUM WALL			
<b>BRAND:</b> NEWKER	<b>CODE:</b> 195222	<b>COLOR:</b> WHITE	<b>DATE:</b> 03/01/2021
<b>CERAMIC TILES CLASSIFICATION (UNE-EN-14411):</b> Grupo BIII. Anexo L			

STANDARD	CHARACTERISTICS	TEST RESULT
UNE-EN ISO 10545-4	Breaking strength	Mín. 700
UNE-EN ISO 10545-4	Modulus of rupture	Mín. 16
UNE-EN ISO 10545-7	Resistance to surface abrasion	
	Class	-
	Abrasion stage	-
UNE-EN ISO 10545-11	Resistance to crazing	Cumple / Passed
UNE-EN ISO 10545-12	Frost Resistance	-
UNE-EN ISO 10545-14	Resistance to staining	
	Fe <sub>2</sub> O <sub>3</sub> / Cr <sub>2</sub> O <sub>3</sub>	5
	Iodine / alcohol solution	5
	Light oil	5
UNE-EN ISO 10545-13	Chemical Resistance	
	Household chemicals	Cumple /Passed
	Swimming pool salts	Cumple / Passed
	Citric Acid	Mín. Gla
	Lactic Acid	Mín. Gla
	Hydrochloric Acid low concentrations	Mín. GLA
	Hydrochloric Acid high concentrations	Mín. GHA
	Potassium Hydroxide low concentrations	Mín. GLA
Potassium Hydroxide high concentrations	Mín. GHA	
<b>Dimension (mm)</b>	300x900	
		<b>Thickness (mm)</b> 8.7
<b>Slipperness</b>		<b>Water absorption</b> E > 10%

new  
ker

NUEVA CERÁMICA NEWKER CA SL  
B-12880357  
C/ Sta. Magdalena de Pulpis, 10  
12006 - CASTELLÓN (SPAIN)